



THE CORPORATION OF THE CITY OF NIAGARA FALLS

ADDENDUM #1

RFT1-2019

SUPPLY & DELIVERY OF READY MIX CONCRETE

CLOSING DATE: Thurs., Mar. 7, 2019 at 1:45 p.m. local time

This addendum shall form an integral part of the Request for Tender (RFT) documents for the above noted RFT and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements as it pertains to the particular and specific items noted below.

This addendum must be signed by the Bidder in the appropriate space and must be attached to the Bidder's Tender submission at the stated time of the closing of the RFT or prior to this time. Tender submissions not including this addendum may be rejected.

QUESTION #1:

There is no mention of minimum cement contents in the specs, however on the Form of Tender, the mixes still list a min. cement content. Can you please clarify which is correct?

ANSWER #1:

The CSA Exposure Class as outlined in the specs should be followed for the unit pricing. When submitting your bid please use *Appendix A: Form of Tender Revision #1*.

The Tenderer shall take due notice of the above noted changes and make allowance for same in the Tender to be submitted to the City of Niagara Falls.

COMPANY NAME:	
TENDERER'S SIGNATURE:	
TENDERER'S NAME: (Please Print)	
DATE:	