



City of Niagara Falls

Contract 2021-534-20
4500 Park Street
Building Decommissioning & Soil Remediation

ADDENDUM # 2

This Addendum shall form an integral part of the contract document for the above noted project and shall be read in conjunction therewith. This Addendum shall, however, take precedence over all requirements of the previously issued contract documents, including plans, with which it may prove to be at variance, unless otherwise clarified by the Engineer.

This Addendum must be signed by the Tenderer in the appropriate space and must be attached to the Form of Tender for submission at the time of tendering. **Tenders not including this Addendum, signed as required, may be rejected as informal.**

To clarify Item #12 on Addendum #1, please see the following statement:

We will permit the use of Granular 'A' or 'B', which can be sourced from a local quarry and may contain limestone. Only virgin material can be used (no recycled materials). As such, this virgin material used as backfill will not be subject to testing at the source.

Date Issued: March 31, 2021

Eric Lallouet
Senior Project Manager

The Tenderer shall take due notice of all revisions/clarifications and make allowance to his/her unit prices.

Signature of Company Representative:	
Name (Please Print):	
Company Name:	
Date:	